

CLASSIFICATION OF CHARACTERISTICS

Nr B/MLTB-332-2010

for preliminary (ITT) tests in accordance with PN-EN 14351-1:2006 standard clauses 4.14, 4.5, 4.2, 4.8



Notified body NB 2189







Company : "PRIMA" Sp. z o.o.

ul. Magazynowa 92, 88-100 Inowrocław

Product : **Windows and balcony doors made from PVC-U profiles of KBE System_88mm**

Test results are included in the following test reports::

MLTB-332-2010-A, MLTB-332-2010-B

Accredited testing methods:					
	Air permeability PN-EN 1026:2001	Waterproofness PN-EN 1027:2001	Wind load resistance PN-EN 12211:2001	Security equipment capacity PN-EN 14609:2006 + 14351-1:2006 pkt. 4.8.	
Classification standards:	PN-EN 12207:2001	PN-EN 12208:2001	PN-EN 12210:2001	Wartość progowa	
Product tested (B x H mm)		CLASS 4 $Q_{100} = 0,38 \text{ m}^3/\text{h.m}$ $Q_{100} = 1,02 \text{ m}^3/\text{h.m}^2$	CLASS E900 Unshaded 900Pa	CLASS C4 1600Pa - 1/300L	350N Threshold value
		CLASS 4 $Q_{100} = 0,41 \text{ m}^3/\text{h.m}$ $Q_{100} = 1,61 \text{ m}^3/\text{h.m}^2$	CLASS 8A Unshaded 450Pa	CLASS C5 2000Pa - 1/449L	350N Threshold value

MOBILNE LTB

head of laboratory

Adam Mścichowski

Inowrocław, 27-07-2010



MOBILNE

Laboratorium Techniki Budowlanej s.c.
Anna Mścichowska, Adam Mścichowski
58-300 Wałbrzych, ul. Jana Kasprówicza 21 lok 2
tel. 0 696 050 073, fax 074 661 41 40
NIP 8862868350, Regon: 020573602



MOBILNE LTB s.c.

A. Mścichowska, A. Mścichowski

NIP PL 8862868350

REGON 020573602

58-300 Wałbrzych, ul. Jana Kasprówicza 21 lok. 2

tel.: +48 696 050 073, fax: + 48 74 6614140

<http://www.mobiltb.pl>

e-mail: biuro@mobiltb.pl

Akredytowane laboratorium

(accredited body) **AB 1054**

Notyfikowana jednostka

(notified body) **NB 2189**